

PORTES AUTOMATIQUES I  
COMPLEMENTS, S.L.  
POL. IND. TORREFARRERA, C/PONENT, 18  
25123 TORREFARRERA  
SPAIN

## Summary of Initial Type Testing Reports for Garage Doors

RISE Research Institutes of Sweden has in its capacity as Notified Body no. 0402 assessed the performance of the construction product in accordance with the harmonized product standard **EN 13241:2003+A2:2016 Industrial, commercial, garage doors and gates** – Product standard, performance characteristics. Performances in this report can be used as support for a *Declaration of Performance* in accordance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR).

This report is a summary of those reports and includes also results from type tests performed by other Notified Bodies. The content of this report may be used as support for an Declaration of Performance in accordance with the CPR. It shall be noted that the client shall specify all the involved Notified Bodies and their numbers in the Declaration of Performance.

### Product name and description

Garage door name/type	RD220 type RSC, RSC-T (2016), RES-X, RES 70, RES 200, RES 350, RS 70, RS 200, RSC-T residential sectional overhead door
Max. weight of door	Depending on spring break device (maximum of 3 springs) or operator, limitation see chapter 1.5 and 3 (Eval. report PX20720-03D, 2013-02-24)
Day-light, maximum	width 5000; height 3000 mm
Day-light, tested	width 2500; height 2610 mm
Panel manufacturer	Metecno Door Panel, Flexi-Force (Full vision), Italpannelli, Marcegaglia
Hardware Flexi-Force	2"track, code 215V, 215VC - rollers 2", code 574RES, 574S, 576, 577, 575-100, 595RSR/F - vertical angle, code 915VB, 915VL - side/lintel seal, code 1085, 1085RB, 1088, 1088T, 1088TF - top seal, code 1036, 1036-36, 1036-52, 1036DN
Balancing system	FlexiForce Torsion / Tension springs
Spring break device	See chapter 1.5
Machinery / Operator	See chapter 3
Bottom seal	See chapter 3

## RISE Research Institutes of Sweden AB

### Postal address

Box 857  
SE-501 15 BORÅS  
Sweden

### Office location

Västeråsen  
Brinellgatan 4  
SE-504 62 BORÅS

### Phone / Fax / E-mail

+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of SP.